

# CFD and Physical Modeling of DSI/ACI Distribution

APC Round Table & Exposition

July 09, 2013

Matt Gentry

Airflow Sciences Corporation  
mgentry@airflowsciences.com  
734-525-0300

# Outline

- ❖ Introduction
- ❖ Flow Analysis Techniques
- ❖ Application to Air Pollution Control Equipment
- ❖ Sorbent Injection Modeling
- ❖ Conclusions


# Introduction

## ❖ Why is Fluid Flow Important to Industrial Equipment?

- Performance
  - Flow uniformity
  - Sorbent injection
  - Ash capture / build-up
- Operating costs
  - Pressure drop
  - Erosion
  - Corrosion
  - Sorbent Usage

## ❖ Applications

- Design of new equipment
- Retrofit of existing equipment
- Solving operational or maintenance issues




# Outline

- ❖ Introduction
- ❖ Flow Analysis Techniques
  - Computational Fluid Dynamics (CFD)
  - Physical Flow Modeling
- ❖ Application to Air Pollution Control Equipment
- ❖ Sorbent Injection Modelling
- ❖ Conclusions

# Computational Fluid Dynamics (CFD)




- ❖ Numerical simulation of flow
- ❖ Utilize high speed computers and sophisticated software
- ❖ Calculate flow properties
  - Velocity
  - Pressure
  - Temperature
  - Species
  - Particle streamlines



# Computational Fluid Dynamics (CFD)

## ❖ Control Volume Approach

- Divide the flow domain into distinct control volumes
- Solve the Navier-Stokes equations (Conservation of Mass, Momentum, Energy) in each control volume





# Physical Flow Modeling

- ❖ Lab representation of geometry
- ❖ Typical scale 1:8 to 1:16
- ❖ “Cold flow” modeling
- ❖ Visualize flow with smoke
- ❖ Simulate ash deposition
- ❖ Measure flow properties
  - Velocity
  - Pressure
  - Tracer gas
  - Dust/Particles



# Physical Flow Modeling

Typical 1:12 scale  
physical model

SDAs

Air Heater Outlet

PJFF  
Compartments

Turning vanes

ID Fan Inlet







# Outline

- ❖ Introduction
- ❖ Flow Analysis Techniques
- ❖ Application to Air Pollution Control Equipment
  - Fabric Filter
  - Sorbent Injection
  - Sorbent Dropout and Deposition
- ❖ Sorbent Injection Modelling Process
- ❖ Conclusions




# Fabric Filter Flow Modeling

- ❖ Uniform velocity distribution and equal balance between compartments
- ❖ Pressure loss
- ❖ Avoid bag erosion
- ❖ Ash deposition



# Mercury / SO<sub>3</sub> Reduction

- ❖ Injection upstream of FF or ESP
  - Activated carbon
  - Lime, Trona, SBC, etc.
- ❖ Uniform injection
- ❖ Maximize residence time
- ❖ Maximize uniformity at FF/ESP



# Ash/Sorbent Deposition


- ❖ Duct floors
- ❖ Turning vanes





# Ash/Sorbent Deposition

- ❖ Drop out
- ❖ Re-entrainment






# Outline

- ❖ Introduction
- ❖ Flow Analysis Techniques
- ❖ Application to Air Pollution Control Equipment
- ❖ Sorbent Injection Modeling
  - Process
  - CFD Applications
  - Physical Modeling Applications
  - Comparison
  - Future Considerations
- ❖ Conclusions

## ❖ Sorbent Injection Modeling: The Process


- 
- The diagram illustrates the 27-km LHC tunnel layout, showing the locations of Vanes (red) and Dampers (cyan) along the beamline. The layout includes a legend and two compass roses indicating orientation.




# Sorbent Injection

## ❖ Sorbent Injection Modeling: The Process



- Discuss the design parameters and restrictions regarding the injection lances (location, number of lance, etc.)
- Perform a baseline flow simulation with the initial injection grid geometry



Average Velocity = 62.5 ft/s  
Streamwise Velocity RMS = 86.8%



Gas Velocity




PAC Injection Concentration


# Sorbent Injection

## ❖ Sorbent Injection Modeling: The Process

- Issue a report with details of the flow and sorbent distribution throughout the model domain



Gas Velocity





PAC Injection Concentration

# Sorbent Injection

## ❖ Sorbent Injection Modeling: The Process

- Particle residence time and sorbent uniformity at the target planes are presented



15-20% is the industry standard for uniformity




# CFD Applications

## ❖ Example 1: Trona and Carbon Injection


Unit 1 - Design 2 - Mass Fraction of Carbon

Isometric View




Unit 1 - Design 2 - Mass Fraction of Trona

Isometric View



# CFD Applications

## ❖ Example 2: Carbon Injection with Multiple Air Heaters



Gas Velocity

PAC Injection Concentration

PAC Injection Balance

# Physical Flow Modeling Applications





# Physical Flow Modeling Applications

- ❖ Lab representation of lance geometry
- ❖ Sorbent injection modeled using tracer gas
- ❖ Gas analyzer used to measure distribution downstream



# Modeling Comparison: CFD/Physical

Target	CFD	Physical
DSI Uniformity – Target Plane 1	6.9%	3.9%
DSI Uniformity – Target Plane 2	9.1%	7.5%
ACI Uniformity – Target Plane 1	11.4%	12.7%

- ❖ Example data comparison from recent projects
  - Data comparable between the two methods
  - Tracer gas testing for other applications (NO<sub>x</sub> distribution, NH<sub>3</sub> injection) confirms good agreement



# Modeling Comparison: CFD/Physical

CFD	Physical
\$	\$\$
Multiple configurations investigated simultaneously	One test at a time
Can include lance details	Lance does not scale (2" dia lance not modeled as 1/6" dia lance)
More data points	Discrete data grid for analyzing mixing
Assumptions related to meshing or algorithm	Assumptions related to scaling and similarity


# Future Considerations

## ❖ Typical Parameters to Consider:

- Do you have enough lances?
- Residence time compared to duct size.
- Is your lance configuration well-suited for the duct aspect ratio?
- Can the plant fans handle dp of a static mixer?
- Substantial internal trusswork?
- You don't necessarily want the most uniform velocity profile at the injection plane.

# Future Considerations


## ❖ Do you have enough lances?



- ❖ 40-45 square feet per lance is a good guideline.
- ❖ Adding more lances after contract award is a tough pill to swallow.


# Future Considerations

## ❖ More Lances = Better Uniformity



# Future Considerations

## ❖ More Lances = Better Uniformity




Cases 1 and 2, the number of lances had to be doubled to approach the uniformity goals.



# Future Considerations

## ❖ More Lances = Better Uniformity





Cases 1 and 2, the number of lances had to be doubled to approach the uniformity goals.

The lance configuration was fixed for Case 3, but the addition of a low dp static mixer proved effective at significantly improving the uniformity.

# Future Considerations


- ❖ Is your lance configuration well-suited for the duct aspect ratio?



Preferred Orientation

# Future Considerations

- ❖ Is your lance configuration well-suited for the duct aspect ratio?



Preferred Orientation

# Future Considerations

- ❖ Mixer?
- ❖ Pressure loss limitations
- ❖ Local or global mixing?
- ❖ Truss location and design



# Future Considerations

## ❖ Modeling vs. Real-Life

- 15%-20% RMS is the industry standard for “uniform” distribution
- RMS required may depend on what is downstream
  - FF > WFGD > ESP
    - How does this compare to actual system effectiveness, “Will I meet my guarantee?”
    - A database of correlation data could be developed based on the many projects that have already been completed in order to give modelers, injection companies, and end users confidence regarding the system performance.

# Conclusions

- ❖ Fluid dynamics and thermodynamics have significant impact on the performance of power plant equipment
- ❖ CFD/Physical modeling is used to optimize the position and arrangement of sorbent injection lances

Better uniformity  Less sorbent usage  Reduced operating cost



# Questions?

Matt Gentry

734-525-0300

[mgentry@airflowsciences.com](mailto:mgentry@airflowsciences.com)